


# **Recall of Furnaces in California**

## **Horizontal furnaces by Consolidated Industries**



### **Gas-fired horizontal furnace**

U.S. Consumer Product Safety Commission (CPSC) announced a recall of about 30,000 furnaces sold in California on July 9, 2001. The units involved are gas-fired horizontal furnaces equipped with steel "NOx" rods installed above the burners and are commonly called NOx rod furnaces. These furnaces pose a substantial risk of fire.

Please get more information at

<http://www.cpsc.gov/CPSCPUB/PREREL/prhtml01/01189.html>